

ALL OF ALL EXISTING AND PROPOSED SERVICES ARE APPROXIMATE AND MUST BE CONFIRMED INDEPENDENTLY WITH LOCAL UTILITY COMPANIES PRIOR TO COMMENCEMENT OF ANY CONSTRUCTION OR EXCAVATION. SANITARY SEWER AND ALL OTHER UTILITY SERVICE CONNECTION POINTS SHALL BE CONFIRMED AND LOCATED ACCORDING TO THE RECORD DRAWINGS AND FIELD SURVEY. ANY DISCREPANCIES SHALL BE REPORTED IMMEDIATELY TO THE ENGINEER. CONSTRUCTION SHALL COMMENCE BEGINNING AT THE LOWEST INVERT (POINT OF CONNECTION) AND PROGRESS UP GRADIENT. INTERFACE POINTS (CROSSINGS) WITH EXISTING UNDERGROUND UTILITIES SHALL BE FIELD VERIFIED BY TEST PIT PRIOR TO COMMENCEMENT OF CONSTRUCTION.

IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO NOTIFY UTILITY "ONE-CALL" NUMBER 72 HOURS PRIOR TO ANY EXCAVATION ON THIS SITE. CONTRACTOR SHALL ALSO NOTIFY LOCAL WATER & SEWER DEPARTMENTS TO MARK-OUT THEIR UTILITIES.

REFER TO ARCHITECTURAL DRAWINGS FOR EXIST BUILDING UTILITY CONNECTION LOCATIONS, WHERE CONFLICTS EXIST WITH THESE SITE PLANS, ENGINEER IS TO BE NOTIFIED PRIOR TO CONSTRUCTION TO RESOLVE SAME. SERVICE SIZES TO BE DETERMINED BY ARCHITECT.

WATER SERVICE MATERIALS SHALL BE SPECIFIED BY THE LOCAL UTILITY COMPANY. CONTRACTORS PRICE FOR WATER SERVICE SHALL INCLUDE ALL MATERIALS AND EQUIPMENTS REQUIRED BY THE UTILITY TO PROVIDE A COMPLETE WORKING SERVICE.

ALL WATER MAIN SHALL BE CEMENT-UNLEADED, CLASS 52 DUCTILE IRON PIPE, UNLESS OTHERWISE DESIGNATED.

3. THE MINIMUM DRAINER FOR DOMESTIC WATER SERVICES SHALL BE 1 INCH.

SEWER MAINS SHALL BE SEPARATED FROM WATER MAINS BY A DISTANCE OF AT LEAST 18 FEET HORIZONTALLY. WHERE THIS IS NOT POSSIBLE, THE PIPES SHALL BE IN SEPARATE TRENCHES WITH THE SEWER MAIN AT LEAST 18 INCHES BELOW THE WATER MAIN. ALL SEWER MAINS SHALL BE SDR-35 PVC PIPE UNLESS OTHERWISE DESIGNATED.

ALL WATER MAINS SHALL BE INSTALLED WITH LESS THAN 3 FEET OF COVER. GREATER THAN 20 FEET OF COVER OR WITHIN 18 INCHES OF A WATER MAIN SHALL BE CONSTRUCTED OF DUCTILE IRON PIPE. ALL DUCTILE IRON SEWER PIPE SHALL BE CEMENT-UNLEADED, CLASS 52 PVC, FURNISHED WITH SEWER COAT, OR APPROVED EQUAL.

WHERE SANITARY SEWER LATERALS ARE GREATER THAN 10" DEEP AT CONNECTION TO THE SEWER MAIN, CONCRETE DEEP LATERAL CONNECTIONS ARE TO BE UTILIZED.

4. THE CONTRACTOR IS RESPONSIBLE FOR THE STABILIZATION OF THE EXISTING SEWER MAIN, STRUCTURES AND APPURTENANCES DURING CONNECTION.

1. LOCATION & LAYOUT OF GAS, ELECTRIC & TELECOMMUNICATION UTILITY LINES AND SERVICES SHOWN ON THESE PLANS ARE SCHEMATIC IN NATURE. ACTUAL LOCATION & LAYOUT OF THESE UTILITIES & SERVICES ARE TO BE PER THE APPROPRIATE UTILITY PROVIDER.

2. ROOF LEADER COLLECTION PIPING ARE CONCEPTUAL IN NATURE AND ARE NOT FOR CONSTRUCTION. ACTUAL ROOF LEADER COLLECTION PIPING IS TO BE COORDINATED WITH ARCHITECTURAL PLANS FOR EACH INDIVIDUAL BUILDING. ALL ROOF LEADER COLLECTION PIPING SHALL BE SCHEDULE 40 PVC UNLESS OTHERWISE DESIGNATED.

3. ALL SEWER AND WATER FACILITIES SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE REGULATORY AUTHORITY'S RULES AND REGULATIONS.

4. ALL PROPOSED UTILITIES TO BE INSTALLED UNDERGROUND UNLESS OTHERWISE NOTED.


5. MANUFACTURED REINFORCED CONCRETE STORM PIPE TO CONFORM TO ASTM C-76, CLASS III, UNLESS OTHERWISE DESIGNATED. MANUFACTURED REINFORCED CONCRETE ELLIPTICAL STORM PIPE TO CONFORM TO ASTM C-507, CLASS II-III, UNLESS OTHERWISE DESIGNATED. REINFORCED CONCRETE STORMWATER PIPE TO BE CONSTRUCTED ACCORDING TO THE LATEST EDITION OF THE AMERICAN CONCRETE INSTITUTE CONSTRUCTION SPECIFICATIONS FOR REINFORCED CONCRETE IN ACCORDANCE WITH ASTM C 990 TO BE UTILIZED TO PROVIDE A SLIT-TIGHT JOINT. WHERE SPECIFICALLY INDICATED, REINFORCED CONCRETE STORM PIPE JOINTS SHALL BE WATERIGHT AND CONFORM TO ASTM C-643.

6. HOPE DRAINAGE PIPE SHALL HAVE A SMOOTH WALL INTERIOR WITH ANNULAR EXTERIOR CORRUGATIONS AND CONFORM TO ASTM F2306. SOLID PIPE SHALL HAVE SMOOTH WALL INTERIOR WITH ANNULAR EXTERIOR CORRUGATIONS AND CONFORM TO ASTM F2306 AND ASTM D3212. PERFORATED PIPE SHALL HAVE GASKETED SLIT-TIGHT JOINTS MEETING THE REQUIREMENTS OF ASTM F2306 AND ASTM F447. HOPE PIPE SHALL BE FROM A MANUFACTURER WHO IS AN EASTERN STATES CONSORTIUM (ESC) QUALIFIED MANUFACTURER OF HOPE PIPE AND INSTALLED IN ACCORDANCE WITH PIPE MANUFACTURER RECOMMENDATIONS.

7. HOPE DRAINAGE PIPE SHALL HAVE A SMOOTH WALL INTERIOR WITH ANNULAR EXTERIOR CORRUGATIONS AND CONFORM TO ASTM F2736 (12"-30" PIPE) AND ASTM F2781 (36"-60" PIPE). PIPE SHALL HAVE GASKETED WATER-TIGHT JOINTS MEETING THE REQUIREMENTS OF ASTM D3212 AND ASTM F447. FIELD WATERTIGHTNESS VERIFICATION MAY BE ACCOMPLISHED IN ACCORDANCE WITH ASTM F2467. HOPE PIPE SHALL BE FROM A MANUFACTURER WHO IS AN EASTERN STATES CONSORTIUM (ESC) QUALIFIED MANUFACTURER OF HOPE STORM PIPE AND INSTALLED IN ACCORDANCE WITH PIPE MANUFACTURER RECOMMENDATIONS.

8. PIPE LENGTHS ON THIS PLAN HAVE BEEN MEASURED AS THE DISTANCE BETWEEN THE CENTER POINT OF THE 2 CONNECTED STRUCTURES. ACTUAL PHYSICAL PIPE LENGTH FOR INSTALLATION IS EXPECTED TO BE LESS AND SHOULD BE ACCOUNTED FOR BY THE CONTRACTOR ACCORDABLY.

Crossing #	Pipe 1 - Top of Pipe	Pipe 2 - Bottom of Pipe	Separation
1	6" SAN, PVC Pipe 88.01'	12" STM, HDPE Pipe 90.95'	2.94'
2	6" SAN, PVC Pipe 88.96'	15" STM, HDPE Pipe 91.25'	2.29'
3	6" SAN, PVC Pipe 90.62'	6" STM, PVC Pipe 94.52'	3.90'



DYNAMIC
• ENGINEERING • EARTH
• SURVEY • TRAFFIC

DATE: 05/18/2021

PROJECT NO: 1423-99-006

SHEET NO: 7

Rev. #:

THIS PLAN SET IS FOR PERMITTING PURPOSES ONLY AND MAY NOT BE USED FOR CONSTRUCTION

SWAIN BR: KHC

DESAND BR: KHC/DRL

DECKED BR: DTS

PROJECT: CSH OLD TAPPAN, LLC
PROPOSED ASSISTED DWING FACILITY

244 OLD TAPPAN ROAD
BOROUGH OF OLD TAPPAN, BERGEN COUNTY, NEW JERSEY

6 05/02/22 REVISED PER BOROUGH & SCD COMMENTS

5 03/16/22 NEW REV PER BOROUGH COMMENTS

4 02/01/22 REVISED PER SCD COMMENTS

3 02/01/22 REVISED PER SCD COMMENTS

2 05/10/23 REVISED PER SCD & COUNTY COMMENTS

1 07/29/23 REVISED PER SCD & COUNTY COMMENTS

GL

JD

MS

GL

GL

BY

811
Know what's below
Call before you dig

FOR STATE SPECIFIC DIRECT PHONE NUMBERS VISIT:
WWW.CALL811.COM

PROTECT YOURSELF

ALL STATES REQUIRE NOTIFICATION OF EXCAVATORS, DESIGNERS, OR ANY PERSON PREPARING TO DISTURB THE EARTH'S SURFACE MINUTES IN ADVANCE

DYNAMIC ENGINEERING

LAND DEVELOPMENT CONSULTING • PERMITTING
GEOTECHNICAL • ENVIRONMENTAL
TRAFFIC • SURVEY • PLANNING & TONING

245 Main Street, Suite 110
Chester, NJ 07930
T: 908.879.9229 F: 908.879.0222

Offices conveniently located at:

Clark County, New Jersey • 732.914.1016

Clermont, New Jersey • 908.991.9229

Newton, New Jersey • 973.752.7250

Long Branch, New Jersey • 732.970.0188

Newark, Pennsylvania • 215.465.0578

Philadelphia, Pennsylvania • 215.553.4689

Allen, Texas • 972.234.2150

Houston, Texas • 281.789.4432

Little Rock, Arkansas • 501.684.0674

Dallas, Texas, Rockstar • 561.921.6020

www.dynamiccec.com

DANIEL T. SEHNAL

PROFESSIONAL ENGINEER
NEW JERSEY LICENSE NO. 53572

JOSEPH G. JAWORSKI

PROFESSIONAL ENGINEER
NEW JERSEY LICENSE NO. 36618

TITLE: DRAINAGE AND UTILITY PLAN

SCALE: (H) 1" = 30'
(V) 1" = 10'

PROJECT NO: 1423-99-006

SHEET NO: 7

DATE: 05/18/2021

Rev. #: